

**SNM COLLEGE
MALIANKARA**

March, 2023



ENERGY AUDIT REPORT



Energy Management Centre - Kerala
(Department of Power, Govt of Kerala)

CERTIFICATE OF EMPANELMENT

*This is to certify that **M/s. Alenso Energy** (N, Ground Floor, Brindavan Business Centre, Manimala Road, Kochi) is empanelled as Energy Audit firm in Energy Management Centre Kerala to conduct mandatory energy audit as per Government of Kerala G.O (Rt) No.2/2011/PD dated 01.01.2011.*

Empanelment No:
EMCEEA-3816F-1

| Scope/Area | Building | Industry -Electrical | Industry Thermal |
|-------------------|-----------------|-----------------------------|-------------------------|
| | Yes | Yes | Yes |

This empanelment is valid up to 01/02/2024

Issuing Date: 02/02/2021

Place: Thiruvananthapuram

Director,
Energy Management Centre Kerala

ENERGY AUDIT REPORT

at

SNM College
Maliankara

March 2023

By

Alenso Energy
N, Brindavan Business Centre,
Manimala Road, Edappally PO
KOCHI - 682 024

Ph: 91 484 2334363 email: energy@alenso.in


Web: www.alenso.in

Acknowledgements

We sincerely thank the management, staff and students of SNM College, Maliankara for giving us an opportunity to evaluate the usage of energy in their facility and co-operating wholeheartedly throughout our audit program. We would like to place on record our special thanks to Dr. Jitha T.H, Principal and Dr. Lakshmi S Bose, Assistant Professor, Physics Department for entrusting this study with us. All employees co-operated wholeheartedly in accompanying us. Still, special mention is due for Ms. Nitha A U, Assistant Professor Economics Department & NAAC Coordinator, Dr. Baiju E C, Assistant Professor Botany Department & IQAC Coordinator, Mr. Dileep, Manager and Mr. Sanoop, Electrician who closely interacted with us on a daily basis. All of them participated enthusiastically in discussions on energy performance. This analysis and report would not have been possible without their inputs and involvement.

Kochi

17.03.2023



Mr. Azeem K

Senior Consultant

Contents

Audit Teamvi

Executive Summary 1

 E.1: Energy Performance 1

 E.2: Energy Saving Proposals 1

Introduction 3

 1.1: Facility Details 4

 1.2: Energy Share 5

Energy & Utility Description..... 6

 2.1: Electricity 6

 2.1.1: Details of Electrical Panels & Distribution Boards..... 6

 2.2: Water..... 7

 2.3: Diesel 8

 2.4: Biogas 8

Energy Performance 9

 3.1: Energy Consumption 9

 3.2: Load Distribution..... 9

Equipment Performance 11

 4.1: Lighting..... 11

 4.2: Pumps 11

 4.3: Air Conditioners..... 12

Climate Impact..... 13

Recommendations for Energy Conservation 14

Appendix..... 19

 Appendix I – Electricity Bill..... 19

 Appendix II – Load Matrix 20

 Appendix III – Layout..... 28

 Appendix III - Abbreviations..... 29

LIST OF TABLES

Table E-1: Summary of Energy Performance 1
Table E-2: Energy Saving Proposals..... 1
Table 1-1: Facility Details 4
Table 2-1: Details of Common Electrical Supply..... 6
Table 3-1: Energy Performance 9
Table 3-2: Category Wise Power Rating and Energy Consumption..... 9
Table 4-1: Lighting Details 11
Table 4-2: Pump Details..... 11
Table 4-3: AC Details 12
Table 5-1: Carbon Emission Details 13
Table 6-1: Summary of Recommendations 14

LIST OF FIGURES

Figure 2.2: (a): Transformer, (b): Main Panel, (c): APFC Panel, (d): SNM College Feeder 7
Figure 2.2: (e): AMF Panel (Main Panel- SNM College), (f): SSB 1, (g): SSB 1A..... 7
Figure 2.3 (a): Well, (b): Storage tank, (C): Rain Water Harvesting tank 7
Figure 2.4: Generator 8
Figure 2.5: Biogas Plant..... 8
Figure 3.1: Energy Consumption Category wise 10

Audit Team

1. Mr. Azeem K , M. Tech, Certified Energy Auditor – EA 3375
2. Mr. Ahammed Kabeer T A , B. Tech (Ele), ME (Energy Engineering), Certified Energy Auditor – EA 1156
3. Dr. Janesh N M, B. Tech (Ele), MSC (Renewable Energy), PhD, Certified Energy Auditor – EA 10690
4. Mr. Ajith M, B. Tech (Ele), Energy Engineer

Executive Summary

E.1: Energy Performance

The energy performance of the facility can be summarized as follows:

Table E-1: Summary of Energy Performance

| Parameter | Electricity | Diesel | LPG | Total |
|--|-------------|-------------|-------------|---------------------|
| Annual Consumption | 84,000 | 612 | 1,140 | 85,897 [#] |
| Unit of measurement | kWh | Ltr. | kg | kWh |
| Annual cost (₹) | 5,23,946 | 57,709 | 1,24,440 | 7,06,094 |
| Unit cost (₹ / unit) | Rs.6.2/kWh | Rs.94.3/Ltr | Rs.109.2/kg | |
| Annual equivalent emission (Tons of CO₂) | 68.9 | 1.6 | 3.4 | 73.9 |
| Built-up area (m²) | 10740.53 | | | |
| Energy Performance Index – EPI (kWh/m²/year) | 7.8 | 0.2 | - | 8.0 |

[#]Based on equivalent power generation estimated from apportioned diesel consumption

The facility have carbon emission equivalent to 74 tons per year. It can be reduced by implementing the proposals recommended below.

E.2: Energy Saving Proposals

Table E-2: Energy Saving Proposals

| Sl. No. | Energy Saving Opportunity | Category | Capital Investment Required | Annual Energy Savings | Annual Financial Savings | Simple Payback Period |
|---------|--|----------|-----------------------------|-----------------------|--------------------------|-----------------------|
| Unit | - | - | ₹ | kWh | ₹ | months |
| 1 | Replace 105 existing tube lights with LED tubes | EE | 47,250 | 3,629 | 25,039 | 23 |
| 2 | Replace 268 existing ceiling fan with energy efficient BLDC fans | EE | 8,57,600 | 15,437 | 1,06,514 | 97 |
| 3 | Replace 3 existing 3 star AC to latest 5 star inverter AC | EE | 1,17,000 | 2,135 | 14,730 | 95 |
| 4 | Install 4 kW off grid solar pv on rooftop | RE | 3,60,000 | 5,840 | 55,498 | 78 |

ENERGY AUDIT REPORT

| Sl. No. | Energy Saving Opportunity | Category | Capital Investment Required | Annual Energy Savings | Annual Financial Savings | Simple Payback Period |
|---------|---|----------|-----------------------------|-----------------------|--------------------------|-----------------------|
| 5 | Install 15 kW on grid solar pv on rooftop | RE | 11,25,000 | 21,900 | 1,51,110 | 90 |
| | Total | | 25,06,850 | 48,940 | 3,52,891 | 86 |

Introduction

Sree Narayana Mangalam College, Maliankara, is a general degree college located in Maliankara, Kerala. It was established in the year 1964. The college is affiliated with Mahatma Gandhi University. This college offers different courses in arts, commerce and science.

SNM College Maliankara symbolises the steady advancement of an underdeveloped village, with its vast population belonging to the backward classes, towards social and cultural regeneration. Its mission has been, as enunciated by the great social revolutionary of Kerala, Sree Narayana Guru, emancipation through education. The institution upholds the message of the great Guru and strives to be a source of enlightenment to the people at large and poor and socially backward, in particular. From its inception in 1964, the college has been rendering commendable service as a centre of learning and culture.

The academic community of the college is totally committed to help evolve a new generation of young people who are just, kind and responsible. The institution's thrust is to impart holistic education to young men and women from all strata of society and develop in them employability and the other skills necessary for being successful in life. The area, where the college is situated, is no more an isolated, underdeveloped part and is on the wings of development and progress.

The college is the legacy of the Vadakkekara Hindu Matha Dharma Paripalana Sabha, a voluntary organisation formed in 1882, by the spirited youth of the backward Ezhava community in the Vadakkekara region. The H.M.D.P. Sabha, Moothakunnam as it is popularly known, launched a vigorous campaign for social justice and liberation from social bondage. The message and the benediction of Sree Narayana Guru provided Inspiration and the right direction to the activities. As part of the movement, the Sabha took initiative in the establishment of educational institutions. The institutions, run by the Sabha, have played a leading role in fighting the evils of illiteracy and ignorance among the poor and downtrodden and raising the cultural standards of the masses. The SNM College, Maliankara is another link in the tradition,

The College was inaugurated in 1964 by Sri.Sahodaran Ayyappan, an ardent disciple of Sree Narayana Guru and also leading public figure championing the cause of social liberty. It was in a cluster of thatched sheds near the Moothakunnam temple that the classes were held in the beginning. The foundation stone for the college building at Maliankara was also laid at that time by Sahodaran Ayyappan himself. The college was shifted to new campus at Maliankara in 1965. The present massive buildings were constructed in subsequent years, providing facilities for the expansion of the college.

Degree Courses were started in 1971, Post Graduate Courses in 1983 and Research centre in 2011. The college has a student strength of more than 2000 at the Under Graduate and Post Graduate levels comprising of 13 Degree Courses, 8 PG Courses, 1 Integrated PG Course and 2 research centres.

Vision of college

"Liberation through Education and empowerment through organisation"

Mission of college

- To institutionalize Guru's philosophy: One Caste, One Religion, One God for Man
- To provide value and need based education to all
- To infuse the spirit of nationalism and patriotism in young minds.
- To bring about an overall development of the students as a whole, especially those who hail from backward sections.
- To contribute to the moral and ethical enrichment of the society

Motto of College

"Enlightenment through Education"

1.1: Facility Details

Table 1-1: Facility Details

| Particulars | Details |
|---------------------------------|--|
| Facility Name | SNM College, Maliankara |
| Address | Maliankara P.O, (Via) Moothakunnam, Ernakulam Dist, Kerala, Pin - 683516 |
| Contact | Ms. Jitha T H, Principal (Mob:+91 94957 42386) |
| Number of staff | 136 |
| Campus Area (Acres) | 26.44 |
| Built-up area (m ²) | 10740.53 |
| Annual Electricity Consumption | 85,897 kWh |
| Annual Energy Cost | Rs. 7,06,094 |

About Campus

The college campus is located in 26.44 acres of land. There are 13 building blocks and 63 classrooms in the campus. The layout of the campus is attached in Appendix III.

1.2: Energy Share




Figure 1.1: Share of energy cost from different sources

The purchased electricity, generated electricity and LPG comprises 80%, 2% and 18% of the total energy consumption respectively.




Figure 1.2: Share of energy cost from different sources

The 76%, 8% and 16% of the total energy cost comprises purchased electricity, generated electricity and LPG respectively.

Energy & Utility Description

2.1: Electricity

Electricity is supplied by Kerala State Electricity Board Limited (KSEBL). Supply falls under high tension category with tariff classification HT- II (B), three phase supply. This electrical supply is common for the SNM Institute of Management Technology, SNM Polytechnic College and SNM College. The details of this common electrical supply are given below.

Table 2-1: Details of Common Electrical Supply

| Utility | | KSEBL | | |
|------------------|---------------|--|------|------------------------------|
| Consumer No. | | 1356080002773 | | |
| Consumer Name | | SNM Institute of Management Technology | | |
| Contract Demand | | 150 kVA | | |
| Connected Load | | 739.19 kW | | |
| Tariff category | | HT-II (B) | | |
| Tariff structure | Item | Rate (₹) | | Amount – monthly average (₹) |
| | Demand Charge | Rs. 500/month | | 61,000 |
| | Energy Charge | Normal | 6.8 | 1,44,100 |
| | | Peak | 10.2 | |
| Off Peak | | 5.1 | | |

The energy charge of tariff HT- II (B) is divided into two slabs based on the telescopic consumption. The facility comes under the lower slab with monthly consumption around 20,100 units and the facility pays energy charge of Rs. 6.8 per unit (Normal zone).

The consumption of the facility is accounted on three time zones with different per unit energy charge in each zone. The energy charge in normal zone (i.e, from 6 am to 6 pm) is Rs. 6.8/unit, in peak zone (i.e, from 6 pm to 10 pm) it is Rs. 10.2/unit and in off peak zone (i.e, from 10 pm to 6 am) it is Rs. 5.1/unit. Apart from the unit power charges, the tariff includes duty on electricity charged at Rs. 0.10 of energy charges. The effective energy rate thus comes to ₹ 6.9 and each unit saved saves the same amount (in normal zone). These charges are likely to be revised upwards in the next financial year.

The SNM College bears only 20% of KSEB bill amount as its share.

2.1.1: Details of Electrical Panels & Distribution Boards

The 315 KVA transformer, KSEB meter and Main panel including feeder for the SNM College are located in substation of SNM Institute of Management Technology. The 11 kV KSEB supply is step down to 420 V by 315 kVA transformer and fed to the main panel and then to the feeders in the individual campuses.

The SNM College have a separate generator for its own usage, having capacity of 125 KVA for the backup power.



Figure 2.2: (a): Transformer, (b): Main Panel, (c): APFC Panel, (d): SNM College Feeder



Figure 2.2: (e): AMF Panel (Main Panel- SNM College), (f): SSB 1, (g): SSB 1A

2.2: Water

The facility uses water for drinking, cooking and sanitation requirements. The sources of water are Municipal water supply and open well. The facility employs a rain water harvesting tank also.



Figure 2.3 (a): Well, (b): Storage tank, (c): Rain Water Harvesting tank

2.3: Diesel

The facility uses diesel for the operation of generator. The facility have a 125 kVA diesel generator for backup power.



Figure 2.4: Generator

2.4: Biogas

The facility employs a biogas plant for the fuel usage in canteen in addition to LPG and wood.



Figure 2.5: Biogas Plant

Energy Performance

3.1: Energy Consumption

Annual Energy Consumption details and trend are given below.

Table 3-1: Energy Performance

| Parameter | Electricity | Diesel | LPG | Total |
|---|-------------|--------|----------|----------|
| Annual Consumption | 84,000 | 612 | 1,140 | 85,897 |
| Unit of measurement | kWh | Ltr. | kg | kWh |
| Annual cost (₹) | 5,23,946 | 57,709 | 1,24,440 | 7,06,094 |
| Built-up area (m ²) | 10740.53 | | | |
| Energy Performance Index – EPI (kWh/m ² /year) | 7.8 | 0.2 | - | 8.0 |

The Energy Performance Index (EPI) is the key metric used for benchmarking energy usage in any commercial building or occupied office spaces. EPI is the energy used per unit area measured on an annual basis in kWh/m²/year.

3.2: Load Distribution

A load refers to the amount of power that a system or device consumes, while energy consumption refers to the amount of energy consumed by the system over a period of time. There are different types of loads employed in the facility such as pumps, lighting, AC etc. These loads vary depending on the operational requirements of the facility. The average load and consumption for different category of the loads is estimated from measured data and the summary for load and energy consumption is presented below.

Table 3-2: Category Wise Power Rating and Energy Consumption

| Category | Load (kW) | Daily Consumption (kWh) |
|-----------|-----------|-------------------------|
| Fan | 30.2 | 104.8 |
| Plug Load | 1.2 | 9.7 |
| Lighting | 13.4 | 48.1 |
| UPS Load | 23.0 | 78.2 |
| AC | 16.8 | 35.1 |
| Pump | 6.4 | 3.0 |
| Total | 91 | 279 |




Figure 3.1: Energy Consumption Category wise

The fans and the UPS load consumes more energy on daily basis which is 38 % and 28 % of total energy consumption.

Equipment Performance

4.1: Lighting

The lighting of the facility includes LED tubes, fluorescent tubes and halogen lights. The total lighting load of the facility is around 13.4 kW and consumes 48 units of energy daily. The street lighting of the facility is around 0.6 kW. The details of lights are given below.

Table 4-1: Lighting Details

| Light Fitting | Nos | Load (kW) | Daily Consumption (kWh) |
|-----------------|------------|-------------|-------------------------|
| LED Tube | 154 | 3.4 | 17.2 |
| Tube | 221 | 8.8 | 26.7 |
| Halogen Bulb | 2 | 0.1 | 1.2 |
| LED Bulb | 11 | 0.2 | 1.8 |
| Square LED | 32 | 0.6 | 0.6 |
| LED Flood light | 3 | 0.1 | 0.6 |
| Total | 423 | 13.2 | 48.1 |

4.2: Pumps

The facility employs 8 water pumps and more than 6 storage tanks. The details of pumps employed by the facility is given below.

Table 4-2: Pump Details

| Sl. No | Area | | Duty | Watts | Nos | kWh |
|--------|--------------|-------------|-------------------------|----------------|-----|-----------------|
| 1 | Canteen | Pump | Upward pumping | 370 | 1 | 0.10 |
| 2 | | Pump | Upward pumping | 370 | 1 | 0.07 |
| 3 | Main Block | Pump | Upward pumping | 1100 | 1 | 0.44 |
| 4 | | Pump | Upward pumping | 750 | 1 | 0.15 |
| 5 | | Filter Pump | Downward pumping | 1500 | 1 | 0.36 |
| 6 | | Pump | Upward pumping | 750 | 1 | 0.45 |
| 7 | | Pump | Upward pumping | 500 | 1 | 0.10 |
| 8 | | Pump | Upward/Downward pumping | 1100 | 1 | 1.32 |
| | Total | | | 6.44 kW | | 2.99 kWh |

4.3: Air Conditioners

The facility employs 10 split air conditioners in different sections. The details of air conditioners employed in the facility are given below.

Table 4-3: AC Details

| Sl. No | Location | Make | TR | Star | EER | Power (W) | Year | No |
|--------|--------------------------|--------|-----|------|------|-----------|------|----|
| 1 | Plant Tissue Culture Lab | Voltas | 1.5 | | | 1650 | | 1 |
| 2 | Microalgal Culture Lab | Lloyd | 1.0 | 3 | 3.60 | 1170 | 2018 | 1 |
| 3 | Seminar Hall | Voltas | 1.5 | 3 | 2.71 | 1860 | 2011 | 2 |
| 4 | Seminar Hall | Lloyd | 2.0 | 3 | 3.39 | 1890 | 2018 | 2 |
| 5 | Multimedia Room | Daikin | 1.5 | 3 | 3.25 | 1970 | 2014 | 2 |
| 6 | Principal Room | Daikin | 1.5 | 3 | 3.25 | 1970 | 2014 | 1 |
| 7 | Principal Room - Office | Voltas | 1.5 | 3 | 2.71 | 1860 | 2011 | 1 |

Climate Impact

The carbon footprint of the facility is the total amount of carbon dioxide (CO₂) and other greenhouse gas emissions produced by the operations of the facility. The main sources of carbon emissions of common utility in the facility are the energy consumed by the pumps, lighting, AC and the fuel used to power the generators. The carbon footprint of the facility is calculated by assessing the emissions associated with the energy consumed and fuel used during the operation of the facility. The annual energy carbon footprint can be tabulated as below:

Table 5-1: Carbon Emission Details

| Parameter | Electricity | Diesel | LPG | Total |
|--|-------------|--------|-------|--------|
| Annual Consumption | 84,000 | 612 | 1,140 | 85,897 |
| Unit of measurement | kWh | Ltr. | Kg | kWh |
| Annual equivalent emission (Tons of CO₂) | 68.9 | 1.6 | 3.4 | 73.9 |

The facility causes emission equivalent to 74 tons of carbon dioxide every year.

The share of different sources in carbon emission can be graphically represented as




Figure 5.1: Share of carbon emission equivalent from different sources

The 92% of carbon emission taken place as a result of usage of purchased electricity, 6% of carbon emission from the LPG and 2% of emission take place as the result of usage of backup power.

Recommendations for Energy Conservation

Our country strives to achieve Net Zero in the future. It is suggested that all our public and private buildings set a model by progressive reduction in energy consumption reflected by the EPI, adopting energy efficient measures and tapping renewable energy potential. The proposals are summarised below.

Table 6-1: Summary of Recommendations

| Sl. No. | Energy Saving Option | Category | Annual Energy Saving | Reduction in emission (Tons of CO ₂) | Remarks |
|--------------|--|----------|----------------------|--|---------|
| 1 | Replace existing tube lights with LED tubes | EE | 3,629 kWh | 3.0 | |
| 2 | Replace existing ceiling fan with energy efficient BLDC fans | EE | 15,437 kWh | 12.6 | |
| 3 | Replace existing 3 star AC to latest 5 star inverter AC | EE | 2,135 kWh | 1.8 | |
| 4 | Install 4 kW off grid solar PV on rooftop | RE | 5,840 kWh | 4.8 | |
| 5 | Install 15 kW on grid solar PV on rooftop | RE | 21,900 kWh | 18.0 | |
| Total | | | 48,940 | 40.1 | |

Minor Recommendations:

1. Avoid wastages by switching off lights in day-lit areas.
2. Switch off extra lights.
3. Human behavior place an important part in energy and equipment usage. Creating awareness among staffs and students thus place an important part in energy conservation. It is recommended to identify innovative ways to improve awareness of staffs and students.
4. Energy conservation posters can be displayed in corridors
5. Measurement forms the first step in energy monitoring and conservation. Monitor the energy consumption of the facility from the meter provided in the AMF feeder in the main panel located in the SNM Institute of Management Technology. For effective monitoring a metering facility may be introduced at the incomer of the facility.
6. Energy efficient pumps to be purchased while replacing the pumps

Detailed calculation and cost benefit analysis of recommendations for energy saving wherever quantified are listed below.

ENERGY SAVING PROPOSAL – 1

Replacement of Fluorescent Tubes with LED (EEM)

Background: Presently the facility employs fluorescent tubes, halogen lights and LED tubes.

Proposal: By replacing the fluorescent tubes with LED of similar length the power consumption will reduce considerably by approximate 50% even with the present operating hours. The calculation for the savings, approximate investment cost and payback period is tabulated below.

| Particulars | Unit | Value |
|--|-------------|-------|
| Power of present tube lights | Watts | 40 |
| Proposed LED tube | Watts | 22 |
| Difference in Wattage | Watts | 18 |
| Average No: of working hours/tube/day | Hrs | 8 |
| No. of tubes | No. | 105 |
| Daily power saving | kWh | 15.12 |
| No: of working days per year (Average) | Nos | 240 |
| kWh Saving per Annum | kWh | 3629 |
| Cost per kWh (Average) | Rs | 6.90 |
| Annual Financial Savings | Rs | 25039 |
| Cost of LED tube | Rs | 450 |
| Investment for LED lights | Rs | 47250 |
| Simple Payback period | Months | 23 |
| Saving in emission | Tons of CO2 | 2.98 |

ENERGY SAVING PROPOSAL – 2

Replacement of existing ceiling fans with energy efficient 5-star rated BLDC fans

Background: Star rating of ceiling fans is a recent development. Presently star rating is based on AC induction motor design improvement. For normal air flow they consume around 55 W of power compared to 75 W consumed by conventional fans. Now fans using BLDC technology are also commercially available which consume around 35 W power only for similar air flow and offer higher saving. These fans take in AC power and internally converts it into DC using SMPS. The main difference between BLDC and ordinary DC fans is the commutation method. A commutation is basically the technique of changing the direction of current in the motor for the rotational movement. In a BLDC motor, as there are no brushes, so the commutation is done by the driving algorithm in the Electronics. The 1200 mm size BLDC fan at dull speed consumes only around 22 to 27W instead of the present ceiling fan with induction motors that takes 60 to 70W as per the manufactures.

Proposal: Replace the ceiling fans with BLDC/BEE star rated fans in main sections of the facility. There are many ceiling fans in the facility. The calculation for the savings is given in the table below.

Ceiling Fan

| Particulars | Unit | With BLDC |
|--|-------------------------|-----------|
| Power of existing ceiling fans at full speed | Watts | 75 |
| Power of replacing fan | Watts | 35 |
| Difference in Wattage | Watts | 40 |
| Avg No: of working hours/day | Hrs | 6 |
| Number of Ceiling Fans operating | Nos | 268 |
| No: of working days per year (Average) | Days | 240 |
| Daily energy saving | kWh/day | 64.32 |
| kWh Saving per Annum | kWh | 15436.8 |
| Cost per kWh (Average) | Rs | 6.90 |
| Annual Financial Savings | Rs | 106514 |
| Cost of replacing Fan per piece | Rs | 3200 |
| Investment for replacing Fan | Rs | 857600 |
| Simple Payback period* | Months | 97 |
| Saving in emission | Tons of CO ₂ | 12.7 |

ENERGY SAVING PROPOSAL – 3

Replacement of existing 3 star Air Conditioners with energy efficient 5-star rated Air Conditioners

Background: Presently the facility employs 3 star rated AC (as per previous classification) in their working areas.

Proposal: Replace 3 star rated Air Conditioners with energy efficient new 5-star rated Air Conditioners. The calculation for the savings is given in the table below.

Air Conditioner

| Particulars | Unit | Plant Tissue Culture Lab | Microalgal Culture Lab | Principal | Total |
|--|-------|--------------------------|------------------------|-----------|--------|
| Power of present 3 Star AC | Watts | 1650 | 1170 | 1170 | 3990 |
| Power of Proposed 5 Star AC | Watts | 1290 | 860 | 860 | 3010 |
| Difference in Wattage | Watts | 360 | 310 | 310 | 980 |
| Average No: of working hours/AC/day | Hrs | 12 | 12 | 6 | 10 |
| No. of AC | No. | 1 | 1 | 1 | 3 |
| No: of working days per year (Average) | kWh | 210 | 210 | 240 | 220 |
| Daily power saving | Nos | 4.3 | 3.7 | 1.9 | 9.9 |
| kWh Saving per Annum | kWh | 907 | 781 | 446 | 2135 |
| Cost per kWh (Average) | Rs | 6.90 | 6.90 | 6.90 | 6.90 |
| Annual Financial Savings | Rs | 6260 | 5390 | 3080 | 14730 |
| Cost of AC | Rs | 45000 | 36000 | 36000 | 117000 |

| Particulars | Unit | Plant Tissue Culture Lab | Microalgal Culture Lab | Principal | Total |
|-----------------------|-------------|--------------------------|------------------------|-----------|--------|
| Investment for AC | Rs | 45000 | 36000 | 36000 | 117000 |
| Simple Payback period | Months | 86 | 80 | 140 | 95 |
| Saving in emission | Tons of CO2 | 0.7 | 0.6 | 0.4 | 1.8 |

ENERGY SAVING PROPOSAL – 4

Install 4 kW off grid solar PV on rooftop

The Sun is an inexhaustible, reliable and non-polluting source of power. Since the inception of life on earth, the only energy that was available came from the sun. Of the numerous renewable sources of energy known to mankind, Solar Photo Voltaic or SPV is one that has the potential to supply power for our future needs.

The facility not have its own KSEB connection and meter. The energy meter is located in another campus, SNM Institute of Management Technology across the road. So, in order to install ongrid solar plant, the facility have its limitations and procedures. So, in first stage we recommend to install a 4 kW off grid solar plant in the roof main building. Investment and saving are summarised below.

| Particulars | Unit | Value |
|---|-------------|---------|
| Proposed plant capacity | kWp | 4 |
| Average Energy Generation | kWh/day | 16 |
| Average Energy Generation | kWh/year | 5840 |
| Present annual unit consumption | kWh/year | 84,000 |
| Average utility electricity cost | Rs | 9.50 |
| Annual Financial Savings from generation | Rs | 55,498 |
| Investment (subsidized & in grid tied mode) | Rs | 360,000 |
| Simple payback period | Months | 78 |
| Saving in emission | Tons of CO2 | 4.8 |

ENERGY SAVING PROPOSAL – 5

Install 15 kW solar PV on rooftop

The Sun is an inexhaustible, reliable and non-polluting source of power. Since the inception of life on earth, the only energy that was available came from the sun. Of the numerous renewable sources of energy known to mankind, Solar Photo Voltaic or SPV is one that has the potential to supply power for our future needs.

If the facility overcomes its limitations to install on grid solar system, then we suggest to install a 15 kw on grid solar Pv on rooftop of main building. Investment and saving are summarized below.

| Particulars | Unit | Value |
|---|-------------------------|-----------|
| Proposed plant capacity | kWp | 15 |
| Average Energy Generation | kWh/day | 60 |
| Average Energy Generation | kWh/year | 21900 |
| Present annual unit consumption | kWh/year | 84,000 |
| Average utility electricity cost | Rs | 6.9 |
| Annual Financial Savings | Rs | 151,110 |
| Investment (subsidized & in grid tied mode) | Rs | 1,125,000 |
| Simple payback period | Months | 90 |
| Saving in emission | Tons of CO ₂ | 18.0 |

Appendix

Appendix I – Electricity Bill

KERALA STATE ELECTRICITY BOARD LIMITED

Office of the Special Officer(Revenue), Pattom,Thiruvananthapuram

DEMAND NOTICE FOR MARCH 2023

(As per CHAPTER VII OF KERALA ELECTRICITY SUPPLY CODE -2014)

| | | | | | | | |
|--|-------------------|------------------|---------------------|---|--------------------|---|------------------------|
| Con. | 135608002773 | Bill Date | 01-Mar-2023 | Due Date | 08-Mar-2023 | Bill No | 21028111047494 Ver : 0 |
| Tariff | HT II (B) GENERAL | Last Date | 23-Mar-2023 | Last Date | 23-Mar-2023 | CD | 371900 BG 0 |
| SNM INSTITUTE OF MANAGEMENT TECHNOLOGY SNM Institute of management Technology Malliankara,B No. VIII/622B, Moothakunnam,North Paravoor,Malliankara, ERNAKULAM,, Mobile no-9446054205 LCN :174584 | | | | SBI Virtual A/c No(IFS Code:SBIN0070493)-KSEBHT17C4584 Consumer GSTIN_ID -KSEB (L)GST ID=32AAECK277NBZ1 Fuel Surcharge@0.09 | | | |
| Arrears as on 31-Jan-2023 | | | | Date of Previous Reading | 31-Jan-2023 | Email: ao@snmimt.edu.in | |
| Disputed | 0 | Undisputed | 0 | Date of Present Reading | 28-Feb-2023 | Supply Voltage | 11 kV HT |
| Contract Demand(kVA) | 75% of CD (KVA) | 130% of CD (KVA) | Connected Load (KW) | Average | | Billing Type | |
| 150.0 | 112.5 | 195.0 | 739.191 | MD (kVA) | Consumption (kWh) | PF | DPS |
| | | | | 112.44 | 20877 | 0.99 | Circle |
| | | | | | | | Ernakulam |
| Reading Details of meter 20002743-Working (KVA,KWh,KVAh & KVArh) for 02-2023 | | | | | | | |
| 1. Energy Consumption(KWh) | | | | 3. Energy Consumption(KVArh) Lag and kVARh (Lead) | | | |
| Zone | FR | IR | MF | Units | Zone | FR | IR |
| 1 | 146649.00 | 139712.00 | 2.000 | 13874 | 1 | 7352.00 | 6855.00 |
| 2 | 29083.00 | 27945.00 | 2.000 | 2276 | 2 | 2027.00 | 1868.00 |
| 3 | 54114.00 | 52016.00 | 2.000 | 4196 | 3 | 4709.00 | 4375.00 |
| Total | | | | 20346 | Total kVArh(Lag) | | |
| | | | | | 1980 kVArh(Lead) | | |
| 2. Energy Consumption(KVAh) | | | | 4. Demand (KVA) | | | |
| Zone | FR | IR | MF | Units | 1 | Readings | MF |
| 1 | 149824.00 | 142844.00 | 2.000 | 13960 | 2 | 51.699 | 2.000 |
| 2 | 29761.00 | 28607.00 | 2.000 | 2308 | 3 | 13.263 | 2.000 |
| 3 | 55469.00 | 53336.00 | 2.000 | 4266 | | 11.841 | 2.000 |
| Total | | | | 20534 | 5.Factory Lighting | | |
| Ave PF=KWh/KVAh | | | | 0.99 | 6.Colony Lighting | | |
| | | | | | 7.Generator | | |
| | | | | | 0 | | |
| INVOICE | | | | | | | |
| | | Unit | Rate | Amount (Rs) | Amount | | |
| 1.Total Demand Charge | | | | 9.Other Charges | | | |
| a. Demand Charge - Normal | 113.0 | 500.000 | 56500.00 | Fuel Surcharge | 1831.14 | | |
| b. Demand Charge - Peak | 0.0 | 500.000 | 0.00 | Reconnection Fee | 0.00 | | |
| c. Demand Charge - Off peak | 0.0 | 500.000 | 0.00 | Charges for Related Payments | 2393.00 | | |
| d. Excess Demand Charge | 0.0 | 250.000 | 0.00 | | | | |
| e. Excess Demand Charge(Peak) | 0.0 | 250.000 | 0.00 | | | | |
| f. Excess Demand Charge (Off) | 0.0 | 250.000 | 0.00 | | | | |
| Sub Total (a+b+c+d+e+f) | | | | 56500.00 | | | |
| 2.Total Energy Charges | | | | | | | |
| a. Energy charges - Normal | 13874 | 6.80000 | 94343.20 | | | | |
| b. Energy charges - Peak | 2276.0 | 10.2000 | 23215.20 | | | | |
| c. Energy charges - Off peak | 4196.0 | 5.10000 | 21399.60 | | | | |
| Sub Total(a+b+c) | | | | 138958.00 | | | |
| 3.PF Incentive / Disincentive | | | | -2779.16 | | | |
| Total Energy Charge | | | | 136178.84 | | | |
| 4.Energy Charges on Lighting load | | | | | | | |
| a.Factory Lighting | 0 | 0.2 | | 10.Total(add 1 to 9) | | | |
| b.Colony Lighting | 0 | 0.2 | 0.00 | 211307.43 | | | |
| Sub Total(a+b) | | | | Plus/Minus (Round off) | | | |
| | | | | -0.43 | | | |
| 5.Electricity Duty | | | | UnDisputed Arr Amount | | | |
| 138958 0.100 13895.80 | | | | 0.00 | | | |
| 6.Ele. Surcharge | | | | Less | | | |
| 20346 0.025 508.65 | | | | 1. Advance / Credit | | | |
| 7.Duty on self generated energy | | | | 0 | | | |
| 0 0.012 0.00 | | | | 2. CD Interest | | | |
| | | | | 0.00 | | | |
| 8.Penalty for non-segn. of light load | | | | 3. CD Refund | | | |
| | | | | 0.00 | | | |
| | | | | Net Payable | | | |
| | | | | 211307.00 | | | |
| (Rupees Two Lakh Eleven Thousand Three Hundred Seven Only) | | | | | | | |
| E & O E | | | | Balance Advance at Credit, if any | | | |
| As per Regulation 130 of Kerala Electricity Supply Code 2014 any complaint regarding accuracy of a bill shall be first taken up with the officer designated to issue the bill (Special Officer(Revenue)). Please follow our official Facebook page fb.com/ksebl for information & announcements.(Please see the instructions overleaf) | | | | | | | |
| SPECIAL OFFICER (REVENUE) | | | | | | | |
| Please Detach and enclose with the DD | | | | | | | |
| 135608002773 | 21028111047494 | Rs.211307.00 | | March 2023 | | | |
| SNM INSTITUTE OF MANAGEMENT TECHNOLOGY | | | | | | | |
| DD/Payment Instruction | Name of the | Date | | | | | Signature |

Appendix II – Load Matrix

| Sl. No. | Area Group | Area | Equipment Category | Equipment | Power Rating (W) | No. Of Devices | No. of rooms | Total No. of Devices | Total Power (W) |
|---------|------------|--|--------------------|--------------|------------------|----------------|--------------|----------------------|-----------------|
| 1 | Main Block | Plant Tissue Culture Lab | Lighting | LED Tube | 22 | 4 | 1 | 4 | 88 |
| 2 | Main Block | | Lighting | LED Tube | 22 | 2 | 1 | 2 | 44 |
| 3 | Main Block | | UPS Load | UPS | 6000 | 1 | 1 | 1 | 6000 |
| 4 | Main Block | | AC | AC | 1650 | 1 | 1 | 1 | 1650 |
| 5 | Main Block | Microalgal Culture Lab | Lighting | LED Tube | 22 | 14 | 1 | 14 | 308 |
| 6 | Main Block | | Lighting | LED Tube | 22 | 2 | 1 | 2 | 44 |
| 7 | Main Block | | Lighting | Tube | 40 | 1 | 1 | 1 | 40 |
| 8 | Main Block | | AC | AC | 1170 | 1 | 1 | 1 | 1170 |
| 9 | Main Block | Fist Funded Centralised Instrumentation & Computer Lab | Lighting | LED Tube | 22 | 1 | 1 | 1 | 22 |
| 10 | Main Block | | Lighting | Tube | 40 | 5 | 1 | 5 | 200 |
| 11 | Main Block | | AC | AC | 2500 | 1 | 1 | 1 | 2500 |
| 12 | Main Block | Room | Lighting | LED Tube | 22 | 1 | 1 | 1 | 22 |
| 13 | Main Block | | Lighting | Tube | 40 | 2 | 1 | 2 | 80 |
| 14 | Main Block | | Fan | Ceiling Fan | 75 | 3 | 1 | 3 | 225 |
| 15 | Main Block | Staff Room | Lighting | Tube | 40 | 2 | 1 | 2 | 80 |
| 16 | Main Block | | Fan | Ceiling Fan | 75 | 4 | 1 | 4 | 300 |
| 17 | Main Block | Physiochemistry Lab | Lighting | Tube | 40 | 2 | 1 | 2 | 80 |
| 18 | Main Block | | Fan | Ceiling Fan | 75 | 4 | 1 | 4 | 300 |
| 19 | Main Block | | Plug Load | Refrigerator | 250 | 1 | 1 | 1 | 250 |

| | | | | | | | | | |
|----|------------|-----------------|-----------|-------------------|-----|----|---|----|-----|
| 20 | Main Block | Research Lab | Lighting | LED Tube | 22 | 2 | 1 | 2 | 44 |
| 21 | Main Block | | Lighting | Tube | 40 | 2 | 1 | 2 | 80 |
| 22 | Main Block | | Fan | Ceiling Fan | 75 | 4 | 1 | 4 | 300 |
| 23 | Main Block | BSC Lab | Lighting | LED Tube | 22 | 2 | 1 | 2 | 44 |
| 24 | Main Block | | Lighting | Tube | 40 | 2 | 1 | 2 | 80 |
| 25 | Main Block | | Fan | Ceiling Fan | 75 | 4 | 1 | 4 | 300 |
| 26 | Main Block | Class Room | Lighting | LED Tube | 22 | 1 | 1 | 1 | 22 |
| 27 | Main Block | | Lighting | Tube | 40 | 1 | 1 | 1 | 40 |
| 28 | Main Block | | Fan | Ceiling Fan | 75 | 4 | 1 | 4 | 300 |
| 29 | Main Block | Zoology BSC Lab | Lighting | Tube | 40 | 16 | 1 | 16 | 640 |
| 30 | Main Block | | Fan | Ceiling Fan | 75 | 4 | 1 | 4 | 300 |
| 31 | Main Block | | Lighting | Incandescent lamp | 60 | 2 | 1 | 2 | 120 |
| 32 | Main Block | | Lighting | CFL | 30 | 1 | 1 | 1 | 30 |
| 33 | Main Block | | Plug Load | Refrigerator | 250 | 1 | 1 | 1 | 250 |
| 34 | Main Block | Zoology MSC Lab | Lighting | LED Tube | 22 | 2 | 1 | 2 | 44 |
| 35 | Main Block | | Lighting | Tube | 40 | 5 | 1 | 5 | 200 |
| 36 | Main Block | | Fan | Ceiling Fan | 75 | 5 | 1 | 5 | 375 |
| 37 | Main Block | Class Room | Lighting | LED Tube | 22 | 1 | 1 | 1 | 22 |
| 38 | Main Block | | Lighting | Tube | 40 | 1 | 1 | 1 | 40 |
| 39 | Main Block | | Fan | Ceiling Fan | 75 | 4 | 1 | 4 | 300 |
| 40 | Main Block | Staff Room | Lighting | Tube | 40 | 2 | 1 | 2 | 80 |
| 41 | Main Block | | UPS Load | UPS | 600 | 1 | 1 | 1 | 600 |
| 42 | Main Block | | Fan | Ceiling Fan | 75 | 4 | 1 | 4 | 300 |

| | | | | | | | | | |
|----|------------|----------------------------------|-----------|-----------------|------|----|---|----|------|
| 43 | Main Block | Office | Lighting | LED Tube | 22 | 8 | 1 | 8 | 176 |
| 44 | Main Block | | Fan | Ceiling Fan | 75 | 9 | 1 | 9 | 675 |
| 45 | Main Block | | UPS Load | UPS | 600 | 6 | 1 | 6 | 3600 |
| 46 | Main Block | | Lighting | Square LED | 20 | 8 | 1 | 8 | 160 |
| 47 | Main Block | Principal Room, Manager Room | Lighting | LED Tube | 22 | 2 | 1 | 2 | 44 |
| 48 | Main Block | | UPS Load | UPS | 600 | 1 | 1 | 1 | 600 |
| 49 | Main Block | | Lighting | LED Flood light | 50 | 2 | 1 | 2 | 100 |
| 50 | Main Block | Principal Room | AC | AC | 1860 | 1 | 1 | 1 | 1860 |
| 51 | Main Block | | AC | AC | 1890 | 1 | 1 | 1 | 1890 |
| 52 | Main Block | Office Room | Lighting | LED Tube | 22 | 2 | 1 | 2 | 44 |
| 53 | Main Block | | Fan | Ceiling Fan | 75 | 5 | 1 | 5 | 375 |
| 54 | Main Block | Chemistry Lab | Lighting | Tube | 40 | 15 | 1 | 15 | 600 |
| 55 | Main Block | | Fan | Ceiling Fan | 75 | 3 | 1 | 3 | 225 |
| 56 | Main Block | | Fan | Exhaust Fan | 30 | 2 | 1 | 2 | 60 |
| 57 | Main Block | | Plug Load | Refrigerator | 250 | 1 | 1 | 1 | 250 |
| 58 | Main Block | Chemistry Instruments & Comp Lab | Lighting | Tube | 40 | 6 | 1 | 6 | 240 |
| 59 | Main Block | | Fan | Ceiling Fan | 75 | 3 | 1 | 3 | 225 |
| 60 | Main Block | Multimedia Room | AC | AC | 1970 | 2 | 1 | 2 | 3940 |
| 61 | Main Block | | Lighting | LED Tube | 22 | 1 | 1 | 1 | 22 |
| 62 | Main Block | | Lighting | LED Flood light | 30 | 1 | 1 | 1 | 30 |
| 63 | Main Block | | Fan | Ceiling Fan | 75 | 1 | 1 | 1 | 75 |
| 64 | Main Block | Staff Room | Lighting | Tube | 40 | 2 | 1 | 2 | 80 |
| 65 | Main Block | | UPS Load | UPS | 600 | 1 | 1 | 1 | 600 |

| | | | | | | | | | |
|----|-----------------|------------------------|----------|-------------|------|----|---|----|------|
| 66 | Main Block | | Fan | Ceiling Fan | 75 | 4 | 1 | 4 | 300 |
| 67 | Main Block | Store & Gas Hall | Lighting | Tube | 40 | 4 | 1 | 4 | 160 |
| 68 | Main Block | | Fan | Ceiling Fan | 75 | 2 | 1 | 2 | 150 |
| 69 | Main Block | BSC Physics Lab | Lighting | Tube | 40 | 15 | 1 | 15 | 600 |
| 70 | Main Block | | Fan | Ceiling Fan | 75 | 3 | 1 | 3 | 225 |
| 71 | Main Block | | Fan | Exhaust Fan | 30 | 2 | 1 | 2 | 60 |
| 72 | Main Block | MSC Physics Lab | Lighting | Tube | 40 | 6 | 1 | 6 | 240 |
| 73 | Main Block | | UPS Load | UPS | 600 | 1 | 1 | 1 | 600 |
| 74 | Main Block | | Fan | Ceiling Fan | 75 | 3 | 1 | 3 | 225 |
| 75 | Main Block | Staff Room | Lighting | Tube | 40 | 2 | 1 | 2 | 80 |
| 76 | Main Block | | Fan | Ceiling Fan | 75 | 4 | 1 | 4 | 300 |
| 77 | Main Block | Electronics Lab | Lighting | Tube | 40 | 6 | 1 | 6 | 240 |
| 78 | Main Block | | Fan | Ceiling Fan | 75 | 3 | 1 | 3 | 225 |
| 79 | Main Block | MSC Physics Class Room | Lighting | LED Tube | 22 | 1 | 1 | 1 | 22 |
| 80 | Main Block | | Lighting | Tube | 40 | 1 | 1 | 1 | 40 |
| 81 | Main Block | | Fan | Ceiling Fan | 75 | 4 | 1 | 4 | 300 |
| 82 | Centinary Block | Library | Lighting | Tube | 40 | 20 | 1 | 20 | 800 |
| 83 | Centinary Block | | Fan | Ceiling Fan | 75 | 16 | 1 | 16 | 1200 |
| 84 | Centinary Block | | UPS Load | UPS | 2000 | 1 | 1 | 1 | 2000 |
| 85 | Centinary Block | Seminar Hall | AC | AC | 1860 | 1 | 1 | 1 | 1860 |
| 86 | Centinary Block | | AC | AC | 1890 | 1 | 1 | 1 | 1890 |
| 87 | Centinary Block | | Lighting | Square LED | 20 | 6 | 1 | 6 | 120 |
| 88 | Centinary Block | | Fan | Ceiling Fan | 75 | 3 | 1 | 3 | 225 |

| | | | | | | | | | |
|-----|-----------------|-------------------------------|----------|-------------|-----|---|----|----|------|
| 89 | Centinary Block | Sree narayana Research centre | Lighting | LED Tube | 22 | 2 | 1 | 2 | 44 |
| 90 | Centinary Block | | Lighting | Tube | 40 | 2 | 1 | 2 | 80 |
| 91 | Centinary Block | | Fan | Ceiling Fan | 75 | 4 | 1 | 4 | 300 |
| 92 | Centinary Block | Staff Cooperative society | Lighting | LED Tube | 22 | 2 | 1 | 2 | 44 |
| 93 | Centinary Block | | Lighting | Tube | 40 | 2 | 1 | 2 | 80 |
| 94 | Centinary Block | | Fan | Ceiling Fan | 75 | 4 | 1 | 4 | 300 |
| 95 | Centinary Block | Toilet | Lighting | LED Tube | 22 | 2 | 2 | 4 | 88 |
| 96 | Centinary Block | | Lighting | Tube | 40 | 2 | 2 | 4 | 160 |
| 97 | Centinary Block | Hindi Department | Lighting | Tube | 40 | 2 | 1 | 2 | 80 |
| 98 | Centinary Block | | UPS Load | UPS | 600 | 1 | 1 | 1 | 600 |
| 99 | Centinary Block | | Fan | Ceiling Fan | 75 | 4 | 1 | 4 | 300 |
| 100 | Centinary Block | English Department | Lighting | Tube | 40 | 2 | 1 | 2 | 80 |
| 101 | Centinary Block | | UPS Load | UPS | 600 | 1 | 1 | 1 | 600 |
| 102 | Centinary Block | | Fan | Ceiling Fan | 75 | 4 | 1 | 4 | 300 |
| 103 | Centinary Block | Malayalam Department | Lighting | Tube | 40 | 2 | 1 | 2 | 80 |
| 104 | Centinary Block | | UPS Load | UPS | 600 | 1 | 1 | 1 | 600 |
| 105 | Centinary Block | | Fan | Ceiling Fan | 75 | 4 | 1 | 4 | 300 |
| 106 | Centinary Block | Class Room | Lighting | LED Tube | 22 | 1 | 13 | 13 | 286 |
| 107 | Centinary Block | | Lighting | Tube | 40 | 1 | 13 | 13 | 520 |
| 108 | Centinary Block | | Fan | Ceiling Fan | 75 | 4 | 13 | 52 | 3900 |
| 109 | Centinary Block | Staff Room | Lighting | Tube | 40 | 2 | 1 | 2 | 80 |
| 110 | Centinary Block | | UPS Load | UPS | 600 | 1 | 1 | 1 | 600 |
| 111 | Centinary Block | | Fan | Ceiling Fan | 75 | 4 | 1 | 4 | 300 |

ENERGY AUDIT REPORT

| | | | | | | | | | |
|-----|-----------------|-------------------|-----------|--------------|-----|----|---|----|------|
| 112 | Centinary Block | Class Room | Lighting | LED Tube | 22 | 1 | 9 | 9 | 198 |
| 113 | Centinary Block | | Lighting | Tube | 40 | 1 | 9 | 9 | 360 |
| 114 | Centinary Block | | Fan | Ceiling Fan | 75 | 4 | 9 | 36 | 2700 |
| 115 | Centinary Block | Health Department | Lighting | Tube | 40 | 2 | 1 | 2 | 80 |
| 116 | Centinary Block | | Fan | Ceiling Fan | 75 | 4 | 1 | 4 | 300 |
| 117 | Centinary Block | Toilet | Lighting | LED Tube | 22 | 2 | 1 | 2 | 44 |
| 118 | Centinary Block | | Lighting | Tube | 40 | 2 | 1 | 2 | 80 |
| 119 | Centinary Block | Class Room | Lighting | LED Tube | 22 | 1 | 9 | 9 | 198 |
| 120 | Centinary Block | | Lighting | Tube | 40 | 1 | 9 | 9 | 360 |
| 121 | Centinary Block | | UPS Load | UPS | 600 | 1 | 1 | 1 | 600 |
| 122 | Centinary Block | | Fan | Ceiling Fan | 75 | 4 | 9 | 36 | 2700 |
| 123 | Centinary Block | Toilet | Lighting | LED Tube | 22 | 2 | 2 | 4 | 88 |
| 124 | Centinary Block | | Lighting | Tube | 40 | 2 | 2 | 4 | 160 |
| 125 | Auditorium | Auditorium | Lighting | Square LED | 20 | 18 | 1 | 18 | 360 |
| 126 | Auditorium | | Fan | Ceiling Fan | 75 | 21 | 1 | 21 | 1575 |
| 127 | Old Block | Class Room | Lighting | LED Tube | 22 | 1 | 9 | 9 | 198 |
| 128 | Old Block | | Lighting | Tube | 40 | 1 | 9 | 9 | 360 |
| 129 | Old Block | | Fan | Ceiling Fan | 75 | 4 | 9 | 36 | 2700 |
| 130 | Old Block | Chemistry Lab | Lighting | Tube | 40 | 6 | 1 | 6 | 240 |
| 131 | Old Block | | Fan | Ceiling Fan | 75 | 3 | 1 | 3 | 225 |
| 132 | Old Block | Canteen | Plug Load | Refrigerator | 250 | 1 | 1 | 1 | 250 |
| 133 | Old Block | | Plug Load | Cooler | 200 | 1 | 1 | 1 | 200 |
| 134 | Old Block - A | Class Room | Lighting | LED Tube | 22 | 1 | 4 | 4 | 88 |
| 135 | Old Block - A | | Lighting | Tube | 40 | 1 | 4 | 4 | 160 |
| 136 | Old Block - A | | Fan | Ceiling Fan | 75 | 4 | 4 | 16 | 1200 |


ENERGY AUDIT REPORT

| | | | | | | | | | |
|-----|-------------------|------------------|----------|--------------|------|---|---|----|------|
| 137 | NCC Building | Room | Lighting | LED Tube | 22 | 2 | 5 | 10 | 220 |
| 138 | NCC Building | | Lighting | Tube | 40 | 1 | 5 | 5 | 200 |
| 139 | SF Block | | UPS Load | UPS | 600 | 5 | 1 | 5 | 3000 |
| 140 | NCC Building | | Fan | Ceiling Fan | 75 | 4 | 5 | 20 | 1500 |
| 141 | RUSA Building | Class Room | Lighting | LED Tube | 22 | 1 | 3 | 3 | 66 |
| 142 | RUSA Building | | Lighting | Tube | 40 | 1 | 3 | 3 | 120 |
| 143 | RUSA Building | | Fan | Ceiling Fan | 75 | 3 | 3 | 9 | 675 |
| 144 | SF Block | Class Room | Lighting | LED Tube | 22 | 1 | 8 | 8 | 176 |
| 145 | SF Block | | Lighting | Tube | 40 | 1 | 8 | 8 | 320 |
| 146 | SF Block | | UPS Load | UPS | 3000 | 1 | 1 | 1 | 3000 |
| 147 | SF Block | | Fan | Ceiling Fan | 75 | 3 | 8 | 24 | 1800 |
| 148 | Block 9 | Class Room | Lighting | LED Tube | 22 | 1 | 3 | 3 | 66 |
| 149 | Block 9 | | Lighting | Tube | 40 | 1 | 3 | 3 | 120 |
| 150 | Block 9 | | Fan | Ceiling Fan | 75 | 3 | 3 | 9 | 675 |
| 151 | Block 10 (Toilet) | Toilet | Lighting | LED Tube | 22 | 2 | 1 | 2 | 44 |
| 152 | Block 10 (Toilet) | | Lighting | Tube | 40 | 2 | 1 | 2 | 80 |
| 153 | Block 11 (Store) | Store | Lighting | LED Tube | 22 | 2 | 1 | 2 | 44 |
| 154 | Block 11 (Store) | | Fan | Ceiling Fan | 75 | 1 | 1 | 1 | 75 |
| 155 | Block 11 (Store) | | Lighting | Tube | 40 | 2 | 1 | 2 | 80 |
| 156 | Block 12 | Womens Rest Room | Lighting | LED Tube | 22 | 1 | 3 | 3 | 66 |
| 157 | Block 12 | | Lighting | Tube | 40 | 1 | 3 | 3 | 120 |
| 158 | Block 12 | | Fan | Ceiling Fan | 75 | 2 | 3 | 6 | 450 |
| 159 | Block 13 | Workshop | Lighting | LED Tube | 22 | 2 | 1 | 2 | 44 |
| 160 | Block 13 | | Fan | Ceiling Fan | 75 | 1 | 1 | 1 | 75 |
| 161 | Block 13 | | Lighting | Tube | 40 | 2 | 1 | 2 | 80 |
| 162 | Common | CB | Lighting | LED Tube | 22 | 4 | 1 | 4 | 88 |
| 163 | Common | | Lighting | LED Bulb | 10 | 1 | 1 | 1 | 10 |
| 164 | Common | | Lighting | Halogen Bulb | 50 | 1 | 1 | 1 | 50 |
| 165 | Common | Main Block | Lighting | LED Tube | 22 | 9 | 1 | 9 | 198 |
| 166 | Common | | Lighting | LED Bulb | 10 | 4 | 1 | 4 | 40 |
| 167 | Common | | Lighting | LED Bulb | 50 | 1 | 1 | 1 | 50 |

ENERGY AUDIT REPORT

| | | | | | | | | | |
|-----|--------|---------------|----------|--------------|------|---|---|---|----------------|
| 168 | Common | | Lighting | Tube | 40 | 1 | 1 | 1 | 40 |
| 169 | Common | Physical Bldg | Lighting | LED Tube | 22 | 2 | 1 | 2 | 44 |
| 170 | Common | Canteen | Lighting | LED Tube | 22 | 1 | 1 | 1 | 22 |
| 171 | Common | Resting Room | Lighting | LED Tube | 22 | 1 | 1 | 1 | 22 |
| 172 | Common | Statue | Lighting | LED Bulb | 10 | 4 | 1 | 4 | 40 |
| 173 | Common | | Lighting | Halogen Bulb | 50 | 1 | 1 | 1 | 50 |
| 174 | Common | Watchhouse | Lighting | LED Bulb | 10 | 1 | 1 | 1 | 10 |
| 175 | Common | Canteen | Pump | Pump | 370 | 1 | 1 | 1 | 370 |
| 176 | Common | | Pump | Pump | 370 | 1 | 1 | 1 | 370 |
| 177 | Common | Main Block | Pump | Pump | 1100 | 1 | 1 | 1 | 1100 |
| 178 | Common | | Pump | Pump | 750 | 1 | 1 | 1 | 750 |
| 179 | Common | | Pump | Filter Pump | 1500 | 1 | 1 | 1 | 1500 |
| 180 | Common | | Pump | Pump | 750 | 1 | 1 | 1 | 750 |
| 181 | Common | | Pump | Pump | 500 | 1 | 1 | 1 | 500 |
| 182 | Common | | Pump | Pump | 1100 | 1 | 1 | 1 | 1100 |
| | | Total | | | | | | | 90.9 kW |

Appendix III – Layout



| | |
|---|-------------------|
| A | Main Block |
| B | Centinary Block |
| C | Auditorium |
| D | Old Block |
| E | Old Block - A |
| F | NCC Building |
| G | RUSA Building |
| H | SF Block |
| I | Block 9 |
| J | Block 10 (Toilet) |
| K | Block 11 (Store) |
| L | Block 12 |
| M | Block 13 |

Appendix III - Abbreviations

CO₂ – Carbon dioxide
DB – Distribution Board
EC – Energy Consumption
EE – Energy Efficiency
EEM – Energy Efficiency Measures
EER – Energy Efficiency Rating
EPI – Energy Performance Index
Hrs – Hours
HT – High Tension
IECC – International Energy Conservation Code
ISO – International Organization for Standardization
KSEBL – Kerala State Electricity Board Limited
kVA – Kilo Volt Ampere
kW – Kilowatt
kWh – Kilowatt hour
LDB – Lighting Distribution Boards
LED – Light emitting diode
Ltr – Liter
M² – Meter Square
MDB – Main Distribution Board
Nos – Numbers
PF – Power Factor
RE – Renewable Energy
Rs – Rupees
Sq. m – Square Meter
Std – Standard
THD – Total Harmonic Distortion
UPS – Uninterrupted Power Supply
V – Volts
W – Watt